

MUNICIPAL CORPORATION, CHANDIGARH
(Fire & Emergency Services)

To

The Principal,
Govt. Model Senior Sec. School,
Sector 39/C,
Chandigarh.


Memo No.CFO/2016/ 595
Dated, Chandigarh, the 3/x/16

Subject: Inspection of fire safety equipments installed in the school building.

Reference memo no.225, dt.28.09.16 & 629, dt.30.09.16 on the subject cited above.

Inspection has been carried out by this department today 03.10.16 and checked the fire extinguishers of the school building for performance which were found working satisfactory at the time of inspection. It is further recommended that all the fire extinguishers should be installed at visible and accessible places. No fire extinguishers should be installed at dead end.

It is further suggested to install rest of the fire safety measures as recommended in the letter dt.12.08.16 under intimation to this office to proceed further in the matter.


Chief Fire Officer
Fire & Emergency Services
Chandigarh

School Code: 24275 | Affiliation No. 2620080

GOVERNMENT MODEL SENIOR SECONDARY SCHOOL

Sector 39-C, Chandigarh.

Phone: 0172-2677006. E-mail: gmhs_39@yahoo.com

No. : GMSSS/39C/2021/ 4307

Dated Chandigarh the :

12-5-2021

To

The Chief Fire Officer
Sector 17, Chandigarh

Subject:- Request for issuing Fire Safety Certificate

It is submitted that as per requirement of the CBSE, for extension of affiliation, a certificate regarding Fire Safety may kindly be issued. Due to time bound procedure Please issue as early as possible

Neesha
12/5/2021
D.P.O.
Principal
Govt. Model Sr. Sec. School,
Sector 39-C, Chandigarh
Sector-39 C, Chandigarh.